



PRODUCT MANUAL FOR
a.c. STATIC TRANSFORMER OPERATED WATTHOUR AND
VAR-HOUR METERS, CLASS 0.2 S, 0.5 S AND 1.0 S
ACCORDING TO IS 14697:1999

This Product Manual shall be used as reference material by all Regional/Branch Offices & licensees to ensure coherence of practice and transparency in operation of certification under Scheme-I of Bureau of Indian Standards (Conformity Assessment) Regulations, 2018 for various products. The document may also be used by prospective applicants desirous of obtaining BIS certification license/certificate.

1.	Product	:	IS 14697:1999
	Title	:	a.c. Static Transformer Operated Watthour and Var-Hour Meters - Class 0.2 S, 0.5 S & 1 S
	No. of Amendments	:	4
2.	Sampling Guidelines:		
a)	Raw material	:	_____
b)	Grouping guidelines	:	Please refer ANNEX – A
c)	Sample Size	:	Three Meters
3.	List of Test Equipment	:	Please refer ANNEX – B
4.	Scheme of Inspection and Testing	:	Please refer ANNEX – C
5.	Possible tests in a day :	:	Please refer ANNEX - D
6.	Scope of the Licence : Licence is granted to use Standard Mark as per IS 14697:1999 with the following scope:		
	Name of the Product	a.c. Static Transformer Operated Watthour and Var-Hour Meters	
	Class 0.2 S / 0.5 S / 1.0 S, Type, Single phase 2-wire/ Three phase 3-wire/ Three phase 4-wire, Voltage.....V, Basic current (I_b)A, Maximum current (I_{max})A, Frequency ...Hz, Connection through voltage transformer / Connection through current transformer only, Insulating Encased/ Non-Insulating Encased, Electro-mechanical register / Electronic display		

ANNEX A

Grouping Guidelines

1. Samples of each variety of meters shall be tested considering the following:
 - i. Accuracy Class - 0.2 S, 0.5 S and 1.0 S
 - ii. Number of phases and wires - Single phase 2-wire, Three phase 3-wire and Three phase 4-wire
 - iii. Insulating encased and non-insulating encased
 - iv. Type of display- Electro-mechanical register, Electronic display
 - v. Connection through Voltage Transformer and connection through Current Transformer only

2. The following relaxation may be given when a variety is tested for all the requirements:
 - i. Same basic current (I_b) and different current ratio (I_{max}/I_b) – One sample of maximum current ratio (I_{max}/I_b) out of the range offered be subjected to all tests.
 - ii. Different basic current (I_b) but same (I_{max}/I_b) – One sample with highest (I_b) be subjected to all tests.
 - iii. Different basic current (I_b) and different (I_{max}/I_b) – One sample with lowest (I_b) and lowest (I_{max}/I_b) and another sample with highest (I_b) and highest (I_{max}/I_b) be subjected to all tests.
 - iv. For CSOL – If same (I_b) with different (I_{max}/I_b) is to be included in the licence, the varieties offered be subjected to tests applicable at I_{max} only.

3. If the licence covers only ‘Electro mechanical register’ and CSOL for ‘Electronic display’ is to be considered, then any one sample with ‘Electronic display’ from any one variety already covered in the license or any new variety intended to be covered in the licence be subjected to all tests or vice-versa.

4. If the license covers only ‘Insulating encased meters’ and CSOL for ‘Non-insulating encased meters’ is to be considered, then any one sample of ‘Non-insulating encased meters’ from any one variety already covered in the license or any new variety intended to be covered in the licence be subjected to all tests or vice-versa.

5. In case of electronic display, manufacturer’s certificate shall be obtained for compliance to the requirement of Clause 6.10 of IS 14697:1999.

6. The Firm shall declare the varieties of ac static transformer operated watt-hour and var-hour meters intended to be covered in the Licence. An undertaking shall also be taken from the applicant/ licensee in respect of construction and design similarity as per clause 3.1.10 of IS 14697:1999 for the range of varieties which they intend to cover in the licence. One set of drawings representing each of these varieties be sealed and kept in the factory for reference whenever required. The Scope of Licence may be restricted based on the Manufacturing and Testing capabilities of the Manufacturer.
7. During the operation of the Licence, BO shall ensure that all the Varieties covered in the Licence are tested in rotation to the extent possible.

ANNEX B**List Of Test Equipment***Major test equipment required to test as per the Indian Standard*

Sl. No.	Test Equipment	Tests used in with Clause Reference
1	Vernier Caliper, Micrometer	Cl. 6.1, 6.2, 6.3, 6.5 & 6.7
2	a.c. High Voltage Tester	Cl. 12.7.6.1, Cl. 12.7.6.3 & Table 21
3	Insulation Tester	Cl. 12.7.6.1, 12.7.6.4 & Table 22
4	Test bench load with phantom system, Reference Standard Meter	Cl.11.1,11.4, 11.5, 12.10.1, 12.13, 23 & Table 23
5	Power Meter	Cl. 9.1.1, 9.1.2, 12.7.1
6	Voltage drop simulation generator	Cl. 9.2.1, 9.2.2, 12.7.2 & Table 11
7	Dust test equipment, Rain Fall Test Equipment	Cl. 6.9, 12.5 & 12.7.6.4
8	Shock Test Device	Cl. 12.3.1
9	Vibration Test Device	Cl. 12.3.2
10	Spring Hammer Test Device	Cl. 12.3.3
11	Impulse Voltage Tester	Cl. 12.7.6.2
12	Glow Wire Test Apparatus	Cl. 6.8, 12.3
13	Short time overcurrent tester	Cl. 9.2.3, 12.7.3, Table 12

The above list is indicative only and may not be treated as exhaustive.

ANNEX C

Scheme Of Inspection And Testing

1. LABORATORY - A laboratory shall be maintained which shall be suitably equipped (as per the requirement given in column 2 of Table 1) and staffed, where different tests given in the specification shall be carried out in accordance with the methods given in the specification.

1.1 The manufacturer shall prepare a calibration plan for the test equipment.

2. TEST RECORDS – The manufacturer shall maintain test records for the tests carried out to establish conformity.

3. LABELLING AND MARKING – As per the requirements of IS 14697:1999.

4. CONTROL UNIT – Meters of the same design manufactured in a day shall constitute a control unit.

5. LEVELS OF CONTROL - The tests as indicated in column 1 of [Table 1](#) and the levels of control in column 3 of [Table 1](#), shall be carried out on the whole production of the factory which is covered by this plan and appropriate records maintained in accordance with paragraph 2 above.

6. REJECTIONS – Disposal of non-conforming product shall be done in such a way so as to ensure that there is no violation of provisions of BIS Act, 2016.

TABLE 1

(1)				(2)	(3)		
Test Details				Test equipment requirement R: required (or) S:Sub-contracting permitted	Levels of Control		
Cl.	Requirement	Test Methods			No. of Sample	Frequency	Remarks
		Clause	Reference				
6.1 to 6.3	General & Constructional requirement	6.1, 6.2, 6.3	IS 14697	R	Each Meter	In case of failure of any meter, cause of failure shall be identified and corrective action shall be taken to remove the non-conformity.	
6.4,6.5	Terminal Blocks and Terminal Cover	6.4, 6.5,6.7		S			
6.8	Resistance to Heat and Fire	6.8, 12.4		Three	Every consignment of insulating material received	No further testing is required if accompanied with Test Certificate.	
6.6	Clearances & Creepage Distances	6.6					S
6.9	Protection against penetration of dust and water	6.9, 12.5			S	Once in six months for each type and rating	In case of failure of any sample, double the number of samples shall be tested and no failure in those samples shall be permitted. After corrective actions samples from two consecutive control units shall be tested and the original frequency may be restored if all the samples pass.
9.6	Immunity to earth fault/phase fault	9.6, 12.17			S		
6.10	Display of Measured Values	6.10		Three	Once in six months for each type and rating	For Cl. 6.10 non-volatile memory supplier's test certificate may also be accepted.	
6.11	Output Device	6.11					R
12.7.6.3	a.c high voltage test	12.7.6.1 12.7.6.3		R	Each Meter	In case of failure of any meter, cause of failure shall be identified and corrective action shall be taken to remove the non-conformity.	
12.7.6.4	Insulation Test	12.7.6.1 12.7.6.4		R			
11.1	Limits of Error due to variation of current	11.1,12.15		R			
11.5	Test of Starting Condition	11.5, 12.13		R			
11.4	Test of no-load condition	11.4, 12.12	R				

9.1	Power Consumption	9.1, 12.7.1		R	Three	Once in six months for each type and rating	In case of failure of any sample, double the number of samples shall be tested and no failure in those samples shall be permitted. After corrective actions samples from two consecutive control units shall be tested and the original frequency may be restored if all the samples pass.
9.2	Influence of Supply Voltage	9.2.1, 9.2.2, 12.7.2		S			
9.2.3	Short time over current test	9.2.3, 12.7.3		S			
9.3	Influence of Self Heating	9.3, 12.7.4		S			
9.4	Influence of Heating	9.4, 12.7.5		S			
10	Electro Magnetic Compatibility	10, 12.8		S	Once in a year for each type and rating		
11.6	Meter Constant	11.6, 12.14		R	Three	Once in six months for each type and rating	
11.7	Repeatability of Error Test	11.7, 12.16		S			
12.3.1	Shock Test	12.3.1		S			
12.3.2	Vibration Test	12.3.2		S			
12.3.3	Spring Hammer Test	12.3.3		S			
8, 12.6	Test for climatic influences	8, 12.6		S			
12.7.6.2	Impulse Voltage Test	12.7.6.1, 12.7.6.2		S			
11.2	Limits of Error due to other influence quantities	11.2, 12.10		S			
11.3	Limits of Error due to ambient temperature influence	11.3, 12.11		S			
							Once in a year for each type and rating

Note-1: Sub-contracting is permitted to a laboratory recognized by the Bureau or Government laboratories empaneled by the Bureau.

Note-2: Levels of control given in column 3 are obligatory in nature. The manufacturer may define the control unit/batch/lot and submit his own levels of control in column 3 with proper justification for approval by BO Head.

ANNEX D

Possible Tests in a day

1. General and Constructional Requirements
2. a.c. High Voltage Test
3. Insulation Test
4. Accuracy Requirements (Limits of Error)
5. Test of starting condition
6. Test of no-load condition
7. Power Consumption